

Notified body No. 1014



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 1014-CPR-0088

In compliance with Regulation (EU) No 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product: Cables
Type: JXFE-R
(accurete identification of cables listed in classification report No. 800305-01/01 CLASS dated 17.04.2018)
Rating: B2_{ca}-s1,d0,a1

placed on the market under the name or trade mark of:

TRANSPORTKABEL-DIXI

and produced in the manufacturing plant:

Reichle & De-Massari Czech Republic a.s.
Vítězství 67, 405 02 Děčín - Děčín XXXIII-Nebočady, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 50575:2014+A1:2016

under system 1+/1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

The test results are stated in the test-report No.: 800305-01/01 of: 17.04.2018, 703256-01/03 of: 12.09.2017

This certificate was first issued on 27.08.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods or the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

27.08.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



Notified body No. 1014

ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 1014-CPR-0089

In compliance with Regulation (EU) No 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product: Power cables with special fire performance

Type: JXFE_R 5x2x0,8; JXFE-R 10x2x0,8; JXFE-R 1x2x0,8
accurate identification of cables listed in classification report No. 703584-01/01 CLASS dated 18.12.2017,
703584-02/01 CLASS dated 18.12.2017, 703256-01/03 dated 18.12.2017

Rating: B_{2ca}-s1,d1,a1; B_{2ca}-s1,d1,a1; B_{2ca}-s1,d0,a1

placed on the market under the name or trade mark of:

TRANSPORTKABEL-DIXI

and produced in the manufacturing plant:

Reichle & De-Massari Czech Republic a.s.
Vítězství 67, 405 02 Děčín - Děčín XXXIII-Nebočady, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 50575:2014+A1:2016

under system 1+/1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.


The test results are stated in the test-report No.: 703584-01/01 of: 25.10.2017, 703256-01/03 of: 12.09.2017

This certificate was first issued on 27.08.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods or the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

27.08.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



802755-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFIKÁT

č.: 1180582

Výrobek: Sdělovací kabely

Typ: JXFE-R

Jmenovité hodnoty: (1 - 30) x 2 x (0,5 - 1,75) mm, 100 V
klasifikace dle ČSN EN 15601-6: B2_{ca}-s1,d0, a1

Objednatel: Transportkabel - DIXI a.s.
Vítězství 67, 405 02 Děčín - Děčín XXXIII-Nebočady, Česká republika

Výrobce: Reichle & De-Massari Czech Republic a.s.
Vítězství 67, 405 02 Děčín - Děčín XXXIII-Nebočady, Česká republika

Výrobní místo: Reichle & De-Massari Czech Republic a.s.
Vítězství 67, 405 02 Děčín - Děčín XXXIII-Nebočady, Česká republika

Obchodní značka: TRANSPORTKABEL-DIXI

Výsledky zkoušek jsou uvedeny v protokolu č.: 601818-01/01 ze dne: 16.05.2016

Vzorek zkoušeného výrobku je ve shodě s požadavky:

IEC 60189-1:07, IEC 60189-2:07, ČSN EN 60811-100:12, ČSN EN 60811-201:12, ČSN EN 60811-202:12, ČSN EN 60811-203:12, ČSN EN 60811-401:12, ČSN EN 60811-501:12, ČSN EN 60811-504:12, ČSN EN 60811-506:12, ČSN EN 60811-508:12, ČSN 347010-82:09, ČSN EN 60332-3-10:10, ČSN EN 60332-3-22:10, ČSN EN 50267-1:99, ČSN EN 50267-2-3:99, ČSN EN 60754-2:15, ČSN EN 61034-1:06+A1:14, ČSN EN 61034-2:06+A1:14, ČSN EN 50399:12, ČSN EN 60332-1-1:05+A1:16, ČSN EN 60332-1-2:05+A1:16

Jiné údaje: TP 09-11 2. vydání, směrnice 22-2012-01

Certifikát byl vydán na základě splnění požadavků certifikačního schématu „EZÚ certifikát“ a na základě smlouvy č. 802755 mezi objednavatelem a Elektrotechnickým zkušebním ústavem.

Shoda výrobku s uvedenými normami a předpisy zajišťuje shodu výrobku se základními požadavky nařízení vlády č. 118/2016 Sb. v platném znění a certifikát může být použit jako podklad pro EU Prohlášení o shodě podle zákona č. 90/2016 Sb. o posuzování shody stanovených výrobků při jejich dodávání na trh, v platném znění.

Platnost certifikátu je omezena do: 31.05.2019

29.08.2018

V Praze dne

Mgr. Miroslav Sedláček
Vedoucí certifikačního orgánu



802755-01