

Fakultní nemocnice Olomouc - venkovní osvětlení

Partner for Contact:
Order No.:
Company:
Customer No.:


Date: 07.12.2016
Operator:

Operator
Telephone
Fax
e-Mail

Fakultní nemocnice Olomouc - venkovní osvětlení / Luminaire parts list


14 Pieces Philips BRP530 GRN25-/740 II DM FG CO GR
Article No.:
Luminous flux (Luminaire): 2105 lm
Luminous flux (Lamps): 2500 lm
Luminaire Wattage: 19.0 W
Luminaire classification according to CIE: 100
CIE flux code: 41 75 97 100 84
Fitting: 1 x GRN25/740 (Correction Factor 1.000).

See our luminaire catalog for an image of the luminaire.




8 Pieces Philips BRP530 GRN55-/740 II DM FG CO GR
Article No.:
Luminous flux (Luminaire): 4597 lm
Luminous flux (Lamps): 5500 lm
Luminaire Wattage: 38.0 W
Luminaire classification according to CIE: 100
CIE flux code: 41 75 97 100 84
Fitting: 1 x GRN55/740 (Correction Factor 1.000).

See our luminaire catalog for an image of the luminaire.




Operator
Telephone
Fax
e-Mail

Situace / 3D Rendering




Operator
Telephone
Fax
e-Mail

Situace / Prostor před vjezdem / Isolines (E, Perpendicular)



Values in Lux, Scale 1 : 101

Position of surface in external scene:
Marked point:
(491.262 m, 1074.563 m, 0.100 m)




Grid: 32 x 32 Points

E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	u0	E_{min} / E_{max}
22	17	32	0.747	0.529


Operator
Telephone
Fax
e-Mail

Situace / Komunikace před objektem / Isolines (E, Perpendicula)



Values in Lux, Scale 1 : 283

Position of surface in external scene:
Marked point:
(512.518 m, 1101.812 m, 0.100 m)




Grid: 128 x 16 Points

E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	u0	E_{min} / E_{max}
28	21	37	0.768	0.570


Operator
Telephone
Fax
e-Mail

Situace / Komunikace parková 1 / Isolines (E, Perpendicular)



Values in Lux, Scale 1 : 233

Position of surface in external scene:
Marked point:
(583.143 m, 1103.084 m, 0.100 m)




Grid: 128 x 64 Points

E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	u0	E_{min} / E_{max}
16	4.29	34	0.261	0.126


Operator
Telephone
Fax
e-Mail

Situace / Komunikace parková 2 / Isolines (E, Perpendicular)



Values in Lux, Scale 1 : 276

Position of surface in external scene:
Marked point:
(520.700 m, 1056.300 m, 0.100 m)



Grid: 128 x 64 Points

E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	u0	E_{min} / E_{max}
18	3.78	34	0.209	0.112